



Council of Enviro Excellence

Date: 01 October 2024

Venue: Hyatt Centric, Janakpuri,  
New Delhi

# **FLEXIBLE OPERATIONS IN THERMAL POWER PLANT**

## Current Coal Flexing Scenario in India, Future Requirements, Challenges & Solutions

Mr Iqbal Hakim  
NTPC Ltd



NTPC Kudgi



NTPC Kayamkulam



NTPC Koldam



# Current Coal Flexing Scenario in India, Future Requirements, Challenges & Solutions


Iqbal Hakim, Senior Manager, NTPC



NTPC Rojmal



NTPC Bhadla



NTPC R&R Colony, Darlipali

Follow us on:



/ntpc1



/ntpcltd1



/ntpclimited



/Company/ntpc



/ntpclimited

Current Status of Flexible Operation & Role of NTPC



Flexible Operation with Indian Coal, Challenges & Supercritical Unit Exemption



Flexing Needs of Future



Issues & Remedial Actions

Boiler

Turbine

Controls

Electrical

Chemistry



Initiatives at Dadri and Simhadri



Regulatory Enablers




NTPC strategy for Flexible Operation







Current Status of Flexible Operation and  
NTPC's role in Meeting Country's Flexing  
Needs

# Need for Flexibilisation: Variable Nature of Demand and Generation



% contribution of coal in all India demand is higher in the months of **January, February and December** and it is lower in the months of July, August and September due to increased generation from Hydro and Wind

Thus, coal flexing needs a more granular approach for optimal utilisation. In longer term, there will need to define the months where coal flexing will be maximum and accordingly assign most flexible units for operation in such months. Flex Ranking of Units needs to be created & best units incentivised.



*For a common Grid, all entities should play by the same rules*

**National Grid**

One nation, one grid. Technically, all grid connected entities should abide by the same rules.

**Nominal Frequency**

Every entity connected to the grid is responsible for maintaining grid frequency near nominal values.


**28%**

NTPC share in Country's Coal based Installed Capacity

**50%**

NTPC share in Country's Coal Flexing

**All Grid connected entities should equally take part in Flexible Operation. 55% MTL rules should be enforced uniformly across all Gencos and Units should be scheduled upto 55%. Moreover, mechanism like SRAS, TRAS, SCED, SCUC etc should also apply uniformly for all Gencos.**



# State Gencos and IPP's should participate in Flexing

## CEA Gazette

CEA Gazette notification dated 30 Jan 2023 envisages all Gencos (including state gencos) to achieve 55% MTL by Jan 2024.


## Operation at 55%

All NTPC stations are operating at 55% MTL. All stations are participating in Markets, Ancillary services, SCED & SCUC.



## Non-Participation

State Gencos & State IPP's are still to follow the above CEA regulations





Flexible Operation with Indian Coal,  
Challenges Faced & Exemption for Super  
Critical Units



# Flexible Operation with Indian Coal

Flexible Operation is manageable with good coal quality (Quality near to design coal).

Indian Power Stations receive coal much worse than the specified worst coal limits. Moreover, a single station may receive coal from multiple sources (More than 6 sources is not uncommon). Even there are huge quality variations in the coal received from a single source. Each source may further have multiple sidings.

Boiler flame stability is not consistent during part load operation due to coal quality (low VM & high ash content and sometimes wet coal). With Indian coal conditions, operating units below 55% load with unstable Boiler flame is challenging even with most advanced flame scanners.

During low load operation with poor coal quality (Low VM, High Ash), the combustion stability of the boiler is severely affected and requires additional support of secondary oil.

Many of the technology provider's and OEMs are exiting the thermal power business, posing serious challenge for availability of technology & solution.

Indian Coal is unique and hence the regulatory requirements must factor in real time coal quality for accessing the flexibility requirements. Flexing with poor coal quality shall adversely impact the reliability of the machines and may lead to power shortages. Provision for variable MTL based on Coal Quality needs to be incorporated in regulations.




## Pilot Studies


- Mouda U# 1 500 MW
- Simhadri U# 1 500 MW
- Dadri U# 6 500 MW



Flame instability due to high coal quality variations in domestic coal (High Ash, Low VM in Indian Coal).




Parametric Excursions.



LP turbine fluttering & may lead to LP blade failure.




Emission issues (Excess wrt norms).



Duct Ash Accumulation.



High Oil Consumption.



May lead to increased BTL.



Electrical Issues

A detailed assessment is needed to establish the Flexing Capability under Indian Coal Conditions



# Exemption of Supercritical Units from Operation Below 55% MTL

## Benson point -switch from wet to dry mode.

Under actual running, generally every boiler comes in wet mode well before the design Benson point due to following:-

1. Each section of boiler i.e. waterwall, economisers, superheaters etc are designed for certain heat absorption at a particular heat input in terms of fuel. If due to any reason i.e. soot deposition, mill combination, coal quality, this heat absorption pattern in boiler changes it affects the actual Benson point.
2. Higher ramping rate leads to wet mode earlier than design.

- The Super-critical units are designed as highly efficient units suited best for base load operation. These units operate at close to 40% efficiency unlike subcritical units whose efficiency is around 35-37%.
- Efficiency of supercritical units degrades very rapidly at part loads.
- Unit comes in wet mode when load goes below 55% as water starts coming in separator. In wet mode CMC goes off automatically and unit is forced to run in manual mode.
- Due to frequent changeover from dry mode to wet mode during load following, BRP pump will also be subject to multiple start stops. Risk of Low eco flow unit trip.
- Frequent opening of separator level control valve.
- In super critical units during Mill trips at lower loads, wide variation in MS temperature is observed which is difficult to contain & unit is liable to trip on HPT stress very high or MS temp very high or low.
- High chances of failure due to thick walled components.
- Chances of LP blade failure will increase at part load.

Benson Points ( Wet-Dry mode Changeover) for Different Supercritical (SC) Boilers

Sl No	Station	Capacity (MW)	Supplier/ Design	Benson Point	
				Design (% of Load)	Actual (% of Load)
1	Sipat Stage 1	3x660	Doosan/ Alstom	30	45-50
2	Barh Stage 2	2x660	BHEL/Alstom	44	50-55
3	Mouda Stage 2	2x660	BHEL/Alstom	44	50-55
4	Kudgi	3x800	Doosan/Babcock	30	40-45
5	Lara	2x800	Doosan/Babcock	30	40-45
6	Meja	2x660	BGRE/HPE	40	45-50
7	Solapur	2x660	BGRE/HPE	40	45-50
8	Gadarwara	2x800	BHEL/Alstom	42	45-50
9	NPGCL	3x660	BHEL/Alstom	44	45-50
10	Darlipalli	2x800	BHEL/Alstom	42	45-50
11	Khargone	2x660	L&T/LMB	30	35-40
12	Tanda	2x660	L&T/LMB	30	35-40
13	NKSTPP	2x660	BHEL/Alstom	44	45-50
14	Telangana	2x800	BHEL/Alstom	44	45-50

In recent incidences when unit was being stopped for planned outage, during ramp down, unit came in wet mode at 50% load in Gadawara and at 47% load at Darlipalli even though the ramp rate below 55% was below 1%. With higher ramp rates below 60% load, wet mode is anticipated earlier.



Flexing Needs of Future


# Capacity Mix by 2030

- As per CEA 2030 plan, the country's capacity mix will change significantly by 2030. Nearly 60 GW capacity needs to be added every year (80% from Solar & Wind) for meeting the energy requirements in 2030.
- By 2030, the share of Solar and Wind will increase from 19% & 10% to 38% & 13%, respectively.


CAGR

- Overall Capacity: 10.2%
- Wind+Solar: 21.7%

FY'24- 442 GW




FY'30- 777 GW



## As more RE is added, Coal Stations would need to Flex through-out the day to accommodate the VRE.

The Coal Stations across the country would need to Flex from 100% LF to about 50% LF. This would test the reliability of Coal stations and present operational, maintenance and commercial challenges.



- By 2030, in certain time blocks the RE generation may be as high as 70%.
- Moreover, for about 1/5th of the time, coal contribution will be lower than 40% necessitating increased turndown levels and possibility of TSO.
- Overall, the Coal PLF shall still be more than 60% mainly due to dependence on coal during non- solar hours.
- Overall Ramping needs will increase to about 1% necessitating automatic load changes.



## Key Issues and Remedial Measures


### Intervention Areas


#	Issues	
1	<b>Combustion Issue at less than 55% load</b> resulting in Unit tripping on Flame Failure. Inadequate Windbox furnace DP during part load can cause furnace disturbance.	Procure flame monitoring systems, Flame Scanners with flicker frequency monitoring, SADC with individual control, Furnace exit temp / CO at ECO outlet / Furnace cameras, improved furnace air damper hardware/controls.
2	<b>High Fatigue in Boiler &amp; Turbine:</b> Variation in MS/HRH temperature shall cause high fatigue in Boiler and Turbine.	<b>Boiler:</b> Upgradation of material in tubes experiencing temperature excursions. Installation of Boiler Fatigue Monitoring System (BFMS) & additional thermo couples for temperature mapping. Replacement of TP 347 H tubes with shot-peened tubes to prevent exfoliation. Extensive preventive NDT / Replacement of high stress points. Replacement /Modification of attachments. Review of existing acceptable standards for tube replacement. <b>Turbine:</b> Increase maintenance due to casing deformation owing to temperature variation. Procure Turbine EOH Calculator. Increase OH frequency. Replacement of capital spares like HPT/IPT/LPT Turbine casing / rotors/bearings at less interval.
3	<b>Frequent opening of TDBFP Recirculation valves</b> due to low load operation	BFP R/c valve to be converted to modulating type. BFP Cartridge replacement frequency to be enhanced.
4	Smooth <b>changeover of BFP</b> control from MCV to ACV & vice versa.	Modifications in drive turbine piping's / valves (CRH / Aux steam source) to be done. Replacement of drive turbine internals to take care of flexible operation.
5	<b>Valve Erosion:</b> Erosion in Main turbine valves, CEP R/c and TDBFP r/c shall increase during part load operation	Valve maintenance to be enhanced. Replacement of valve trim/internals to take care of erosion
6	<b>LPT blade failure:</b> Increased potential of LPT blade failure due to blade fluttering due to frequent change of operating conditions	Blade vibration monitoring system (VMS) to be installed and maintenance intervention to be further increased.
7	<b>Excessive exhaust hood spray</b> leading to LPT blade erosion	LPT Blade replacement frequency to be enhanced owing to enhanced erosion
8	Variation of load in generator shall cause <b>life consumption of generator</b> . Frequent operation of equipment's during ramp up/down to 40% i.e. breakers, motors	Maintenance and OH practices needs to be reviewed. Component replacement frequency to be increased.
9	At low load, samples do not come properly at <b>SWAS</b> Cooler	Flow control valves to be installed for Feed water, Boiler water, Separator tank, Saturated steam, Main steam & HRH sample flows.
10	<b>Ash accumulation</b> Due to low flue gas velocity at 40% load, duct ash accumulation shall take place.	Provision of hoppers in FG duct at identified zones of ash accumulation
11	<b>NOx</b> values are increasing at low load due to high excess air	Changes are required in regulations for low load operation
12	<b>Premature failure</b> of equipment	Increase in frequency of overhauls, increased preventive maintenance, early equipment replacement/repair etc
13	<b>Supercritical units</b> are not fit for 40% load operation	Unit comes in wet mode and CMC goes Off, Machine cannot be run in auto.



# Boiler: Issues and Mitigation Measures

Sl. No	Issues	Mitigation Action/Action Plan
1	Poor flame intensity at 40% load operation, and any outage of mill may cause flame failure.	Enhancing reliability of milling system.
2	Inadequate WB-Furnace DP during part load can cause furnace disturbance	SOFA /COFA/BOFA dampers to be kept closed to ensure adequate SA for combustion , same to be tuned for 40% load operation (NOx shall increase with this action)
3	PA Fan may go to stall as it shall be operation at very low load at 40% load	Real time Operating Point on PA fan stalling curve to be provided as PA Fan shall operate near to stall.
4	Variation in MS/HRH temperature shall cause high fatigue in Boiler and Turbine.	Upgradation of material in tubes experiencing temperature excursions. Boiler Fatigue Monitoring System to be installed to assess boiler damage including installation of additional thermo couples for temperature mapping. Replacement of TP 347 H tubes with shotpeened tubes to prevent exfoliation. Extensive preventive NDT / Replacement of high stress points. Replacement /Modification of attachments. Review of existing acceptable standards for tube replacement.
5	Primary & secondary air temp will come down at low loads so SCAPH needs to be charged.	SCAPH needs to be revived wherever not available. Increased frequency of APH Soot Blowing
6	Due to frequent operation of SH/RH Spray erosion of valve shall increase	Valve maintenance to be enhanced.
7	Minimum total air flow to be restricted to 1050 -1100 tph to avoid improper combustion & ensuring adequate flue gas velocity to avoid ash accumulation in ducts.	Logic to be implemented based on input from Operation
8	NOx values are increasing at 40% load due to high excess air	Policy advocacy is required for increasing the values at low load
9	Erosion of APH outlet flue gas damper flaps due to prolonged throttling operation	Replacement of damper flaps during Overhauls
10	Due to low flue gas velocity in flue gas ducts at 40% load, duct act ash accumulation shall take place.	Provision of hoppers in FG duct at identified zones of ash accumulation
11	SH spray limitation: Saturation temp limit is acting at low load in SH spray control due to less MS pressure, specially operating with sliding pressure mode.	Pressure curve to be reviewed further.



# Turbine: Issues and Mitigation Measures

Sl. No	Issues	Mitigation Action/Action Plan
1	Frequent opening of TDBFP Recirculation valves due to low load operation	BFP R/c valve to be converted to modulating type
2	Poor Drum level control: During less pressure operation slightest of the disturbance in furnace is causing fluctuations in drum level leading to swing in drum level & consequently spray control.	Loop tuning for 40% prolonged load operation.
3	Smooth changeover of BFP control from MCV to ACV & vice versa (Modifications to be done in turbine piping's).	Modifications in drive turbine piping's / valves (CRH / Aux steam source) to be done. Replacement of drive turbine internals to take care of flexible operation.
4	Variation in MS Temperature and material degradation /deformation in casing/rotor due to temperature variation. High vibration of rotor train due to frequent ramp up / ramp down	Increase maintenance intervention in turbine area due to casing deformation owing to temperature variation, Turbine EOH calculation to be made available. Frequency of OH of turbine shall be increased owing to reduced life of turbine due to flexibilisation. Replacement of capital spares like HPT/IPT/LPT Turbine casing / rotors/bearings to take of material degradation due to flexible operation / temperature & pressure swing.
5	Erosion in Main turbine valves, CEP R/c and TDBFP r/c shall increase during part load operation	Valve maintenance to be enhanced. Replacement of valve trim/internals to take care of erosion
6	Increased potential of LPT blade failure due to blade fluttering due to frequent change of operating conditions	Blade vibration monitoring system to be installed and maintenance intervention to be further increased.
7	Excessive exhaust hood spray leading to LPT blade erosion	LPT Blade replacement frequency to be enhanced owing to enhanced erosion
8	As variation in BFP Flow at 40% plays a key role for stable drum level maintaining in auto. variation in BFP flows at same speed to be minimized.	BFP Cartridge replacement frequency to be enhanced.
9	Erosion of Heaters drip CVs / piping	Replacement of drip CV's internals / Drip piping due to erosion



Chemistry		
1	In Subcritical unit CPU flow to be kept stable	Modulating-type pneumatic bypass valve to be installed in CPU service vessel system (if not envisaged in design). Also, logic needs to be modified to get maximum/full condensate flow through one CPU service vessel during part load operation of unit.
2	At 40% load, samples does not properly come at SWAS Cooler	Flow control valves to be installed for Feed water, Boiler water, Separator tank, Saturated steam, Main steam & HRH sample flows.
Electrical		
1	frequent operation of equipments during ramp up/down to 40% i.e. breakers, motors	Maintenance and OH practices needs to be reviewed.
2	variation of load in generator shall cause life consumption of generator	Maintenance and OH practices needs to be reviewed.
C&I		
1	Controls enhancement for low load operation	Shall be carried out as per requirement
2	Flame Scanners with flicker frequency monitoring	TO be procured
3	SADC with individual control	TO be procured
4	High precision blade pitch actuators	TO be procured
5	Furnace exit temp / CO at ECO outlet / Furnace cameras for better monitoring	TO be procured



## Processes Implemented

- ✓ Intelligent Proactive Process control
  - (MS HRH temp, Flue gas temp. etc.)
- ✓ Single drive operation (Higher Efficiency & Lower Reliability)
- ✓ Automated Milling System
- ✓ Condition monitoring system
- ✓ Combustion Optimisation
- ✓ Boiler Fatigue Monitoring system (BFMS)
- ✓ Unit Response Optimisation (Reduce Over & Undershoots)

## Work with M/s Siemens & Emerson

---

**Hardware E&C (Control panel, BFP/c valves replaced)**

---

**ID, FD ,PA , Mill SGC**

---

**Sliding pressure implementation**

---

**TDBFP and MDBFP SGC**

---

**BFMS : Commissioning done**

---

**Condensate throttling, Unit control, Drum & S/H control**





**Regulatory Enablers**

# Regulatory Provisions

## Tariff Regulations 2024-29:

**Regulation 19 (2 and 3):-**The **Capital Cost** of a new/existing project shall include the following:

Expenditure required to enable flexible operation of the generating station at lower loads.

**Regulation 26 Additional Capitalization** beyond the original scope

Works required ...towards enabling flexible operation of the generating station...

Tariff Regulations 2024-29: 1st Amendment						
Loading %	Coal Stations			Gas Stations		
	% Increase in HR		% Decrease in APC	% Increase in HR		% Decrease in APC
	Sub Critical	Super Critical		CC	OC	
85-100	Nil	Nil	Nil	Nil	Nil	Nil
80-<85	2.1	1.8	0.5	2.5	3	0.25
75-<80	3	2.5	1.1	5	7	0.5
70<75	4	3.3	1.1	5	7	0.5
65-<70	5.1	4.1	1.8	8	11	0.8
60-<65	6.1	4.9	1.8	8	11	0.8
55-<60	7.6	6	2.5	12	16	1.2
50-<55	9.2	7.1	2.5	12	16	1.2
45-<50	11.3	8.3	3.2			
40-<45	13.8	9.9	3.2			

**SOC below 55% MTL= 0.2 ml/ kWh.**

Tariff Regulations 2019-24			
LF(%)	HeatRate(Kcal/kWh)		APC (%)
	Super-Critical	Subcritical	
85-100	Nil	Nil	Nil
75-85	1.25	2.25	0.35
65-75	2	4	0.65
55-65	3	6	1

Start up Condition (IEGC 2023)		
Condition	S/D (Hrs)	T/B Metal Temp below full load
Hot	<10	80%
Warm	10-72	40% to 80%
Cold	>72	<40%

The CERC Tariff Regulations 2024-29 is an enabler for Flexible Operation. CERC shall allow the Capital Costs and provide part load compensation for operation at below normative levels. **Increase in O&M cost to be provided.**


**Stations which declare flexibilisation (Monthly Basis) may be provided additional Flex O&M charges.**





## NTPC Strategy for Variable Load Operation

# 3-Pronged Strategic Approach for Variable Load Operation



## Technology

- Control & Monitoring System for early warning & smooth operation
- Schematic & Technological/Metallurgical upgrades
- Partnership (National/Global)

## Technical Up-gradation

- OEM/Expert Support
- Boiler Combustion System
- Boiler Fatigue Monitoring System
- Vibration Monitoring System
- Control Optimization etc



## Process

- Capital OH reduced from 6 to 4 Yrs.
- Optimisation of Overhauling Interval
- Control Loop Tuning
- Studies- OEM/ Experts

## Regulatory Support

- Higher Incentives for Voluntary low load contribution.
- Uniform implementation for all grid connected entities irrespective of Ownership
- Coal Quality.



## People

- Training & Development.
- Centralized Tuning group
- Collaboration with International agencies like EPRI, JICA etc
- Simulator training







NTPC Kudgi



NTPC Kayamkulam



NTPC Koldam



Thank You

Iqbal Abdulla Hakim

Senior Manager (Strategic Initiatives & Information Services, NTPCLtd)

[iqbalhakim@ntpc.co.in](mailto:iqbalhakim@ntpc.co.in)

+91-7006088160



NTPC Rajmal



NTPC Bhadla



NTPC R&R Colony, Darlipali

Follow us on:

/ntpc1

/ntpcltd1


/ntpclimited

/Company/ntpc


/ntpclimited

# Scheduling Summary for 11 Sep 2024


## PH (29900) MW




## NPH (27010) MW







## (DARLIPALI) 1600 MW



## (RGUNDAM-I&II) 2100 MW































NPH Stations

08-Sep-2024












# Gujarat Scheduling

MW	IC	DC	SG	Min SG
GSECL	1900	1786	1250	70.0%



# States Flexing as per Grid India Report for 4 Aug 2024

Cap On Bar (MW)	Gen at Max Freq (MW)	55% Cap	Min Load
33335	23451	18341	75%

**Freq 50.39 Hz at 12:02:30 hrs**

S.No.	Station	State	Cap On Bar (MW)	Gen at Max Freq (MW)	55% Cap	Min Load
1	RAYALASEEMA TPP	ANDHRAPRADESH	1440	860	792	64%
2	Marwa (2*500)	CHATTISGARH	1000	919	550	98%
3	KORBA EAST	CHATTISGARH	250	230	138	98%
4	WANAKBORI	GUJARAT	1010	669	556	70%
5	Ukai	GUJARAT	700	445	385	68%
6	GANDHINAGAR(GTPS)	GUJARAT	210	145	116	73%
7	BLTPS (2*250)	GUJARAT	250	162	138	69%
8	KLTPS (2*75)	GUJARAT	75	58	41	82%
9	RGTPP( KHEGAR)( 2 "	HARYANA	1200	744	660	66%
10	KODERMA(2*500)	JHARKHAND	1000	642	550	68%
11	BOKARO-A'(1"500)	JHARKHAND	500	341	275	73%
12	TENUGHAT(2"210)	JHARKHAND	420	282	231	71%
13	RAICHURTPS	KARNATAKA	1090	721	600	70%
14	JP BINA (2"250)	MADHYA	250	141	138	60%
15	TATA TROMBAY Th	MAHARASTRA	250	270	138	115%
16	DAHANU (2*250)	MAHARASTRA	500	284	275	60%
17	IB.TPS ( 2 * 210 )	ODISHA	420	317	231	80%
18	RAJPURA(NPL) TPS( 2	PUNJAB	1400	1318	770	100%
19	TALWANDI SABO TPS	PUNJAB	1320	1037	726	84%
20	LEHRA MOHABBAT	PUNJAB	710	634	391	95%
21	GGs TPS (ROPAR)	Punjab	840	703	462	89%
22	GOINDWAL(GVK)	Punjab	270	231	149	91%
23	KOTA TPS	RAJASTHAN	1240	936	682	80%
24	CHHABRA	RAJASTHAN	2320	1484	1276	68%
25	Rajwest IPP	RAJASTHAN	945	725	520	82%

S.No.	Station	State	Cap On Bar (MW)	Gen at Max Freq (MW)	55% Cap	Min Load
26	Kawai	RAJASTHAN	1320	852	726	69%
27	Barsingar	RAJASTHAN	250	169	138	72%
28	Kalisindh	RAJASTHAN	600	361	330	64%
29	Mettur	Tamil Nadu	1440	923	792	68%
30	ST CMS	Tamil Nadu	250	170	138	72%
31	North Chennai	Tamil Nadu	600	347	330	62%
32	KOTHAGUDEM TPS	Tamil Nadu	1550	1113	853	76%
33	Singreni	Uttar Pradesh	600	441	330	78%
34	JAWAHARPUR	Uttar Pradesh	660	383	363	62%
35	Obra	Uttar Pradesh	800	449	440	60%
36	Sagardighi	West Bengal	1100	789	605	76%
37	Mejia	West Bengal	710	540	391	81%
38	Mejia 2	West Bengal	1000	681	550	72%
39	Kalaghat	West Bengal	630	447	347	75%
40	RTPS	West Bengal	600	425	330	75%
41	Bakreshwar	West Bengal	840	542	462	69%
42	Santalidh	West Bengal	500	323	275	69%
43	Bandel	West Bengal	275	198	151	77%
			<b>33335</b>	<b>23451</b>	<b>18341</b>	<b>75%</b>



# Flame failure data for FY-23-24

Reason	Type of Boiler	Nos	Reason for Trip
Flame Failures due to equipment outage	All Boiler	17	Equipment outage
Flame failure at Part Load	Corner fired	25	Lean mixture
	Wall fired	1	Lean mixture
Flame failure at Full Load	Corner fired	3	Fall of Ash
	Wall fired	5	Fall of Ash
		5	Improper combustion
Total		56	

Recently in Tanda U6 flame failure took place at 55 % load with stable unit parameters. After analysis of coal quality, it was observed that ash content was more than 50% & Volatile matter in coal was less than required in 3 Mills.


Design Coal = 3300 kcal/kg

Mill	Moisture	Ash	VM	GCV
Mill B	4.3 %	52.5 %	22.9 %	3018 Kcal/kg
Mill C	3.4 %	49.9%	16.1%	3336 Kcal/kg
Mill D	3.8%	52%	20.4%	3120 Kcal/kg
Mill E	2.1%	54.2 %	15.3%	3062 kcal/kg
Mill G	3.9 %	58%	18.7%	2575 kcal/kg





# Ramagundam unit 7 flame study observation during 40% load:


- Flame intensity is drastically reduced.
- Tests were conducted during different time of year & on both instances, flame condition was not observed to be healthy.
- Flame intensity trends are given below



# Mouda flame study observation during 40% load:



# High Fatigue BTL



**As boiler will be subjected to maximum temp variation, exfoliation related issues will rise further**



Stator windings degradation

Degradation of electrical insulation causing electrical shorts, partial discharges, or complete winding failure.

Looseness of core leading to failure of Generators, motors & transformers.

Increased failure of breakers.

Cyclic loading causes repeated heating and cooling of the generator components, leading to thermal fatigue.

Expansion and contraction of the generator casing.

Components wear out faster leading to higher maintenance costs and potential downtimes.

Reduction in actual life of components & regular Inspection and Monitoring, Component Upgrades.

Motor shaft /coupling failures.



# LP Turbine Blade Failure Report

results have shown that L-OR blades in steam turbines are sensitive against back pressure variation at certain operating conditions. The dynamic blade excitation rises due to aerodynamic phenomena in low load or part load operation with an elevated level of back pressure. The aerodynamically induced vibration of the last-stage blade is a function of the volumetric flow and the back pressure. Rotating instabilities cause higher non-synchronous excitation of the last stage blade in a certain load range and will increase with higher backpressure levels.

A continuous operation of the last stage blades (see figure 1) at certain load points can cause elevated blade vibrations which results in an increased blade lifetime consumption. The risk of





## Start-up Oil Consumption for Super Critical Units per Cold start-up (KL/Start)



<b>NTPC Stations</b>	<b>18-19</b>	<b>19-20</b>	<b>20-21</b>	<b>21-22</b>	<b>22-23</b>	<b>AVERAGE (KL/Start)</b>
SOLAPUR STPS (2 x 660 MW)	748	319	277	217	259	<b>364</b>
KUDGI STPS (3 x 800 MW)	320	357	293	349	285	<b>321</b>
LARA STPS (2 x 800 MW)	-	-	316	251	262	<b>276</b>
TANDA ST-II (2 x 660 MW)	-	383	515	252	422	<b>393</b>
SIPAT ST-I (3 x 660 MW)	688	600	814	409	575	<b>617</b>
MAUDA ST-II (2 x 660 MW)	143	181	86	183	210	<b>160</b>
GADARWARA (2 x 800 MW)	-	377	489	571	396	<b>458</b>
KHARGONE (2 x 660 MW)	-	-	364	220	314	<b>299</b>
BARH ST-II (2 x 660 MW)	640	735	430	175	232	<b>442</b>
NABINAGAR (3 x 660 MW)	-	176	272	254	233	<b>234</b>
DARLIPALLI (2 x 800 MW)	-	175	395	338	399	<b>327</b>
<b>Average Oil Consumption per Cold start up (KL/Start)</b>						<b>354</b>



**THANKING YOU!**  
**ON BEHALF OF**



**Council of Enviro Excellence**